

REQUEST FOR SITE APPROVAL

To: Hardy County Health Department, Moorefield, WV

From: Name: BRENT BOBBO / Phone 257 3536

Address PO BOX 59 OLD FIELDS WV 26836

RE: Property Location WESTERLY LAKE LOT 6

Request is hereby made for a site investigation to determine the suitability of the subject property as a site for small sewage system indicated below:

Septic System     Pit Privy     Vault Privy     Other

The results of a percolation test conducted in accordance with the requirements of Design Standards for Small Septic Tank Systems follows:

Depth of test holes: #1 24, #2 24, #3 24, #4 24 inches.

Time for water to fall 6 inches in test hole	#1	<u>315</u>	minutes
	#2	<u>319</u>	minutes
	#3	<u>317</u>	minutes
	#4	<u>319</u>	minutes
	Total	<u>1370</u>	minutes.

52 in  
Avg

400 sq ft  
Bedroom

A test hole bored or dug 6 feet deep  has  has not been provided to help determine the depth to bedrock and ground water table.

On the back of this form a plot layout has been sketched showing the property lines and relative locations of buildings, water supplies, percolation test holes, six ft. hole, and other pertinent features.

I (we), the undersigned, certify that the information contained herein is correct and accurate to the best of my (our) knowledge. It is further understood that this form is not an application for a permit, and subsequent acceptance of this site by the designed health department does not constitute a permit to install a sewage system.

Owner's Signature [Signature] / Date 05/24/07

Percolation test conducted by: Name: BRENT BOBBO JOE STARK

Address: PO BOX 59 OLD FIELDS WV 26836

Date: 05/24/07 / Signature [Signature]

For Health Department Use Only

This is to certify that the Hardy County Health Department reviewed the contents of this form and conducted a site visit on subject property. Based on the information provided it is the opinion of the undersigned that this site  is  is not Suitable for the installation of the small sewage system indicated.

Signature and Title Will Oney / Sect Date 5/25/07

\* Septic must be located where perk was done, if changing new perk Required